



Testa protokols

Pasūtījums PD6_izklausanas

Serijs: P1-5

Tests: Universal test

Standarts: Without standard

Paraugs: Universal sample

Izgatavosanas datums: 25.11.2020 14:14

Parauga vecums: 57 02:58

Testa datums: 21.01.2021 17:12

Testus veica: A. Dandens

Pasūtītājs U. Skadinš

Name	Maksimālās vērtības
1	Piston 3,29 mm Load 1165,7 kN
2	Piston 3,29 mm Load 1170,2 kN
3	Piston 3,43 mm Load 1203,4 kN
4	Piston 3,45 mm Load 944,1 kN
5	Piston 3,17 mm Load 1185,5 kN
6	Piston 3,27 mm Load 1172,0 kN
7	Piston 3,02 mm Load 1165,1 kN
8	Piston 3,44 mm Load 1140,9 kN
9	Piston 3,26 mm Load 1170,1 kN
10	Piston 3,09 mm Load 1159,2 kN
11	Piston 3,31 mm Load 1182,0 kN
12	Piston 3,12 mm Load 1128,3 kN

